

RWS&S PALASA DIVISION
CHEMICAL ANALYSIS OF WATER SAMPLES

Sample Sent by :
Mandal : Palasa
Village : Ramakrishnapuram
Location : Sri sathyasai vidyavihar
Source Of Wate : B.W

Collected Date : 23.07.2021
Received Dat : 23.07.2021
Tested Date : 24.07.2021
Bore No :
Lab Ref No : 1257

RESULTS

The Following Values are expressed in Mg/Lt Unless Otherwise Stated

Sl.No.	Name Of Test	As per Lab report	Acceptable	Allowable
1	Turbidity	0	1 N.T.U.	5 N.T.U.
2	PH	7.21	6.5	8.5
3	Electrical Conductivity	74	200 Micro Hos/Cm	2000 Micro Hos/Cm
4	Total Dissolved Solids	48	500	2000
5	Total Alkalinity	42	200	600
6	Total Hardness as CaCo3	10	200	600
7	Calcium Ca	2.4	75	200
8	Chloride Cl	14.18	200	1000
9	Fluoride F	0.05	1.0	1.5
10	Total Iron Fe	0	0.1	1.0
11	Sulphates SO4	1	200	400
12	Magnesium	0.972	50	150
13	Nitrate (NO3)	0	0	45
14	Coliform in 100ml	<2	0	10
15	E coli in 100ml	0		


REMARKS. :---

Chemically & Bacteriologically satisfactory

B. Preethi Chandhury
PRINCIPAL
SRI SATHYA SAI VIDYA VIHAR
RAMAKRISHNAPURAM, Palasa Mdl.
Srikakulam Dist. (A.P.) - 532 243

I. Sathish Kumar
Assistant Chemist
I.W.Q.M.LABORATORY
R.W.S & S. PALASA

M. Ramesh
CORRESPONDENT
SRI SATHYA SAI VIDYAVIHAR
RAMAKRISHNA PURAM, Palasa Mdl.



SANITATION CERTIFICATE

Certified that Sri Sathya Sai Vidya Vihar, Ramakrishnapuram Building Survey No. 143, Patta No. 26, at Ramakrishnapuram of Gurudasapuram Panchayat, Palasa Mandal, Srikakulam District, Andhra Pradesh., for running school is suitable from Public Health Point of View.

Sunil 13/3/21
Medical Officer
Primary Health Center
RENTIKOTA

B. Preethi Choudhury
PRINCIPAL
SRI SATHYA SAI VIDYA VIHAR
RAMAKRISHNAPURAM, Palasa Mdl
Srikakulam Dist. (A.P.) - 532 243

M. Ramesw
CORRESPONDENT
SRI SATHYA SAI VIDYAVIHAR
RAMAKRISHNA PURAM, Palasa Mdl.